

Fire Protection System Maintenance Requirements

Type of System		Every 6 Months		Annually
Portable Fire Extinguishers				X
Kitchen Hood Systems	After every discharge	X		
Kitchen Hood Cleaning	3 months for heavy use	6 months, normal use, sooner if needed		Annually, Light use(once a week), sooner if needed
Fire Alarm System		Some Components		At Least Annually
Fire Pumps		And After Activations		X
Fire Suppression Sprinkler Systems		And After Activations		X
Alternative Fire Suppression System				X
Stand Pipe Systems				X
Smoke Control Systems				X
Emergency Condition Alarm				X